

Report

Page 1 (14)



T1619695

1ZJECQ6WAT4



Date received **2016-08-22**
Issued **2016-08-31**

Mátis ohf
Hrólfur Sigurdsson
Food Research, inn. and safety
Vinlandsleid 12
IS-113 Reykjavik
ICELAND

Project
Reference

Analysis of drinking water

Your ID	R16-2260-1/Nes/						
LabID	O10793925						
Analysis	Results	Uncertainty (\pm)	Unit	Method	Issuer	Sign	
Ca	3.23	0.25	mg/l	1	R	FREN	
Fe	0.0281	0.0024	mg/l	1	R	FREN	
K	<0.4		mg/l	1	R	FREN	
Mg	0.943	0.063	mg/l	1	R	FREN	
Na	4.02	0.30	mg/l	1	R	FREN	
Si	4.71	0.29	mg/l	1	R	FREN	
Al	0.551	0.168	μ g/l	1	H	FREN	
As	0.0760	0.1140	μ g/l	1	H	FREN	
Ba	<0.01		μ g/l	1	H	FREN	
Cd	<0.002		μ g/l	1	H	FREN	
Co	<0.005		μ g/l	1	H	FREN	
Cr	0.119	0.026	μ g/l	1	H	FREN	
Cu	7.00	1.40	μ g/l	1	H	FREN	
Hg	<0.002		μ g/l	1	F	FREN	
Mn	0.308	0.064	μ g/l	1	H	FREN	
Mo	<0.05		μ g/l	1	H	FREN	
Ni	0.203	0.042	μ g/l	1	H	FREN	
P	5.69	1.14	μ g/l	1	H	FREN	
Pb	0.0502	0.0106	μ g/l	1	H	FREN	
Sr	2.63	0.30	μ g/l	1	R	FREN	
Zn	18.5	2.4	μ g/l	1	R	FREN	
V	1.04	0.21	μ g/l	1	H	FREN	
Sb	<0.01		μ g/l	2	H	FREN	
B	<10		μ g/l	3	R	FREN	
S	0.336	0.058	mg/l	4	R	FREN	
Se	<0.5		μ g/l	5	H	FREN	
benzene	<0.20		μ g/l	6	1	WIDF	
toluene	<0.20		μ g/l	6	1	WIDF	
ethylbenzene	<0.10		μ g/l	6	1	WIDF	
m,p-xylene	<0.20		μ g/l	6	1	WIDF	
o-xylene	<0.10		μ g/l	6	1	WIDF	
xylenes, sum*	<0.20		μ g/l	6	1	WIDF	
dichloromethane	<2.0		μ g/l	7	1	WIDF	
1,1-dichloroethane	<0.10		μ g/l	7	1	WIDF	
1,2-dichloroethane	<0.50		μ g/l	7	1	WIDF	
trans-1,2-dichloroethene	<0.10		μ g/l	7	1	WIDF	
cis-1,2-dichloroethene	<0.10		μ g/l	7	1	WIDF	
1,2-dichloropropane	<1.0		μ g/l	7	1	WIDF	
tetrachloromethane	<0.10		μ g/l	7	1	WIDF	
1,1,1-trichloroethane	<0.10		μ g/l	7	1	WIDF	

Report

Page 2 (14)



T1619695

1ZJECQ6WAT4



Your ID	R16-2260-1/Nes/					
LabID	O10793925					
Analysis	Results	Uncertainty (±)	Unit	Method	Issuer	Sign
1,1,2-trichloroethane	<0.20		µg/l	7	1	WIDF
trichloroethene	<0.10		µg/l	7	1	WIDF
tetrachloroethene	<0.20		µg/l	7	1	WIDF
vinylchloride	<1.0		µg/l	7	1	WIDF
naphthalene	<0.20		µg/l	8	1	WIDF
acenaphthylene	<0.10		µg/l	8	1	WIDF
acenaphthene	<0.0070		µg/l	8	1	WIDF
fluorene	<0.010		µg/l	8	1	WIDF
phenanthrene	<0.040		µg/l	8	1	WIDF
anthracene	<0.0050		µg/l	8	1	WIDF
fluoranthene	<0.0050		µg/l	8	1	WIDF
pyrene	<0.0050		µg/l	8	1	WIDF
benzo(a)anthracene	<0.0030		µg/l	8	1	WIDF
chrysene	<0.0070		µg/l	8	1	WIDF
benzo(b)fluoranthene	<0.0040		µg/l	8	1	WIDF
benzo(k)fluoranthene	<0.0020		µg/l	8	1	WIDF
benzo(a)pyrene	<0.0020		µg/l	8	1	WIDF
dibenzo(ah)anthracene	<0.0020		µg/l	8	1	WIDF
benzo(ghi)perylene	<0.0030		µg/l	8	1	WIDF
indeno(123cd)pyrene	<0.0030		µg/l	8	1	WIDF
PAH, sum 16*	<0.20		µg/l	8	1	WIDF
PAH, sum carcinogenic*	<0.012		µg/l	8	1	WIDF
PAH, sum non carcinogenic*	<0.20		µg/l	8	1	WIDF
PAH, sum 4*	<0.0060		µg/l	8	1	WIDF
PAH, sum L*	<0.20		µg/l	8	1	WIDF
PAH, sum M*	<0.040		µg/l	8	1	WIDF
PAH, sum H*	<0.013		µg/l	8	1	WIDF
trichloromethane	<0.30		µg/l	9	1	WIDF
tribromomethane	<0.20		µg/l	9	1	WIDF
dibromochloromethane	<0.10		µg/l	9	1	WIDF
bromodichloromethane	<0.10		µg/l	9	1	WIDF
trihalomethanes, sum*	<0.35		µg/l	9	1	WIDF
ammonium	<0.026		mg/l	10	1	WIDF
chloride	3.20	0.480	mg/l	11	1	WIDF
colour	<5		mgPt/l	12	2	NEMA
sulphate	1.17	0.176	mg/l	13	1	WIDF
TOC	<0.50		mg/l	14	1	WIDF
nitrate	<0.022		mg/l	15	3	STGR
nitrite	<0.01		mg/l	16	2	NIVE
fluoride	<0.200		mg/l	17	1	WIDF
CN total	<0.005		mg/l	18	1	WIDF
Resultaten m.a.p. tidskänsliga parametrar är osäkra p.g.a. tiden från provtagning till analys har överskridits.						